

**OFFICE OF THE DISTRICT MEDICAL & HEALTH OFFICER
RANGA REDDY DISTRICT.**

At Shivarampally, Rajendranagar, Hyderabad, Telangana State.




Rc.No.1823/D&O/DM&HO/RR/2025

Dated: 04-06-2025

SANITARY CERTIFICATE

I hereby declared that Health Inspector inspected the **M/s Oasis School of Excellence,**
Located at Ammapally, Shamshabad (Mandal), Ranga Reddy District. Building premises
and the accommodation provided for each of the several classes is sufficient for the
maximum number of Pupils taught therein, and is properly ventilated and lighted, that the
building is maintained is substantial repairs, that is neat and clean, that the urinals & latrines
arrangements are adequate and satisfactory that the supply of drinking water is wholesome,
and that in all other necessary respects the Hygienic and sanitation is good for the Academic
year **2025-2026.**

This certificate should be got renewed starting of every academic year by applying to the
District Medical & Health Officer, R.R. District.


District Medical & Health Officer,
Ranga Reddy District, Officer
Dist. Medical & Health Officer
Ranga Reddy District

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
Directorate of I.P.M,P.H.Labs, Food (H) Administration, Narayanaguda.

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1. Sample From: Oasis School Of Excellence, Ammapally, Shamshabad, R R Dist .

2. Collected by: A.Ramulu, Gardener (Samples collected by Party)

3. Collected on : 04-06-2025

4. Received on: 04-06-2025

Lab. Ref. No.	Source	Exact location	Residual Chlorine mg per liter	Total coliform bacteria (MPN Index) per 100ml	Faecal coliform bacteria per 100ml	Esch. coli per 100ml	Result
7222	Borewell water	Borewell water collected at above address	Nil	Satisfactory
7224	R.O water	R.O plant water collected at above address	Nil	Satisfactory
7225	R.O water(TPC)	R.O plant water collected at above address	Total Aerobic Bacterial Plate Count for 24 hrs at 37 ⁰ c = 1 CFU / ml				Satisfactory

Channai
17/6/25
Dy. Chief Water Analyst

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
 Directorate of I.P.M,P.H.Labs, Food (H) Administration, Narayanaguda, Hyderabad – 29.

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER						
Sample From		Oasis School Of Excellence,		Collected by		A.Ramulu, Gardener (Samples collected by Party)
Address		Ammapally, Shamshabad, R R Dist .		Collected on		04-06-2025
District		Hyderabad		Received on		04-06-2025
State		TS		Sample volume		2 ltr
Source profile		Borewell water / R.O water		Sample ID		7223 / 7226
S.No	Parameter	Source / Sample ID		Drinking Water -Specification As per IS 10500 :2012		
		Borewell water collected at above address / 7223	Direct R.O water collected at above address / 7226	Requirement (Acceptable)	Permissible limit in the absence of alternative source	
Physical parameters						
1	colour(Hazen),max	<5	<5	5	15	
2	Turbidity (NTU),max	1.10	0.39	1	5	
3	Odour	UnObjectionable	UnObjectionable	UnObjectionable	UnObjectionable	
4	Taste	Agreeable	Agreeable	Agreeable	Agreeable	
5	p ^H	7.5	6.5	6.5 - 8.5	No relaxation	
6	Electrical Conductivity at 25°C (Micro Mhos/cm)	992	103	
7	TDS(mg/L),max	655	67	500	2000	
Chemical parameters (mg/L)						
1	Alkalinity(as CaCO3) ,phenolphthalein ,max	Nil	Nil	
2	Total alkalinity (as CaCO3) ,max	280	27	200	600	
3	Total hardness (as CaCO3),max	304	15	200	600	
4	Calcium hardness (as CaCO3),max	196	9	
5	Magnesium hardness (as CaCO3),max	108	6	
6	Calcium (as Ca),max	78.4	3.6	75	200	
7	Magnesium (as Mg),max	26.3	1.4	30	100	
8	Ammonical Nitrogen,max	Nil	Nil	
9	Nitrite(as N),max	Nil	Nil	
10	Nitrate(as N),max	5.6	1.4	45	No relaxation	
11	Sulphate (as SO4),max	4	Nil	200	400	
12	Chloride(as Cl),max	64	11	250	1000	
13	Fluoride(as F),max	1.20	0.03	1.0	1.5	
14	Iron (as Fe),max	Nil	Nil	0.3	No relaxation	

Remarks: The sample with Lab Ref No: 7223 are physico chemically unsatisfactory as total hardness & fluoride values are above acceptable limit.

The sample with Lab Ref No: 7226 is physico chemically satisfactory.

Signature
12/6/25